

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: ██████████
 CustomerID: ██████████
 CustomerPO: ██████████
 ProjectID: ██████████

Attn: ██████████ Phone: (215) 729-3220
REACT Environmental Prof Svcs Grp, Inc. Fax:
6901 Kingsessing Avenue Received: 11/22/19 4:25 PM
Suite 201
Philadelphia, PA 19142
 Project: 0P7514.240.01

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
KITCHEN 001 KITCHEN SINK FAUCET ON GROUND FLOOR- INITIAL		11/22/2019 5:45:00 AM	011914999-0001		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/22/2019 SK	11/22/19 17:55 SK
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
KITCHEN 002 KITCHEN SINK FAUCET ON GROUND FLOOR- FLUSH		11/22/2019 5:50:00 AM	011914999-0002		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/22/2019 SK	11/22/19 18:00 SK
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
WF1-001 GROUND FLOOR WATER FOUNTAIN- INITIAL		11/22/2019 5:46:00 AM	011914999-0003		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/22/2019 SK	11/22/19 18:01 SK
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
WF1-002 GROUND FLOOR WATER FOUNTAIN- FLUSH		11/22/2019 5:52:00 AM	011914999-0004		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/22/2019 SK	11/22/19 18:03 SK
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
WF2-001 1ST FLOOR WATER FOUNTAIN- INITIAL		11/22/2019 5:53:00 AM	011914999-0005		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/22/2019 SK	11/22/19 18:04 SK

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: [REDACTED]
 CustomerID: [REDACTED]
 CustomerPO: [REDACTED]
 ProjectID: [REDACTED]

Attn: [REDACTED] Phone: (215) 729-3220
REACT Environmental Prof Svcs Grp, Inc. Fax:
6901 Kingsessing Avenue Received: 11/22/19 4:25 PM
Suite 201
Philadelphia, PA 19142
 Project: 0P7514.240.01

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
WF2-002 1ST FLOOR WATER FOUNTAIN- FLUSH		11/22/2019 5:59:00 AM	011914999-0006		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/22/2019 SK	11/22/19 18:23 SK
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
WF3-001 2ND FLOOR WATER FOUNTAIN- INITIAL		11/22/2019 5:55:00 AM	011914999-0007		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/22/2019 SK	11/22/19 18:25 SK
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
WF3-002 2ND FLOOR WATER FOUNTAIN- FLUSH		11/22/2019 6:01:00 AM	011914999-0008		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/22/2019 SK	11/22/19 18:26 SK
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
WF4-001 3RD FLOOR WATER FOUNTAIN-INITIAL		11/22/2019 6:01:00 AM	011914999-0009		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/22/2019 SK	11/22/19 18:28 SK
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
WF4-002 3RD FLOOR WATER FOUNTAIN-FLUSH		11/22/2019 6:08:00 AM	011914999-0010		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/22/2019 SK	11/22/19 18:29 SK

Definitions:

MDL - method detection limit
 J - Result was below the reporting limit, but at or above the MDL
 ND - indicates that the analyte was not detected at the reporting limit
 RL - Reporting Limit (Analytical)
 D - Dilution